

KEY NOTES:

- 1 1/2" TRAP PRIMER LINE. PROVIDE AND INSTALL HEAT TRACE. COORDINATE WITH ELECTRICAL DRAWINGS FOR MORE INFORMATION.
- 2 ROUTE 4"SW DN TIGHT TO COLUMN. INSTALL A 4"WCO AT BASE OF STACK. REFER TO SHEET P1.0 FOR CONTINUATION.
- 3 6"SD FROM ABOVE
- 4 1-1/2"HUB DRAIN FOR MECHANICAL UNIT BELOW BEAMS.
- 5 4"SD FROM ABOVE.
- 6 ROUTE 6"SD DN TIGHT TO COLUMN BELOW. SEE SHEET P1.0 FOR CONTINUATION.
- 7 ROUTE 4"SD DN TIGHT TO COLUMN BELOW. SEE SHEET P1.0 FOR CONTINUATION.
- 8 ROUTE 3"SW DN TIGHT TO COLUMN. INSTALL A 3"WCO AT BASE OF STACK. REFER TO SHEET P1.0 FOR CONTINUATION.
- 9 ROUTE 2"SW DN TIGHT TO COLUMN. INSTALL A 2"WCO AT BASE OF STACK. REFER TO SHEET P1.0 FOR CONTINUATION.
- 10 2"V UP IN WALL ABOVE.
- 11 ROUTE 2"CD TIGHT TO COLUMN. REFER TO SHEET P1.0 FOR CONTINUATION.
- 12 ROUTE 3"SD DN TIGHT TO COLUMN. INSTALL A 3"WCO AT BASE OF STACK. REFER TO SHEET P1.0 FOR CONTINUATION.

NOTES:


1. ALL EXPOSED SW PIPING TO BE HEAT TRACED. COORDINATE WITH ELECTRICAL FOR ELECTRICAL REQUIREMENTS. PROVIDE AND INSTALL RAYCHEM XL-TRACE 5XL1CR, 120V MAXIMUM 30 AMPS WITH THERMOSTAT TO BE SET AT 40°F.
2. PROVIDE CELLULAR GLASS INSULATION ON EXPOSED SW PIPING BELOW BEAMS. PROVIDE JOHN MAINSVILLE ZESTON 300 SERIES HIGH IMPACT, UV RESISTANT PVC JACKETING ON EXPOSED PIPING DOWN COLUMNS.
3. ROUTE PIPING TIGHT TO STRUCTURE BETWEEN BEAMS. DROP PIPING TO BELOW BEAM AS REQUIRED.
4. PROVIDE SLEEVES FOR ALL PIPING PENETRATIONS THROUGH SLAB.

1 FLOOR PLAN - BELOW FLOOR PLUMBING

SCALE: 1/8" = 1'-0"



**Allen&Hoshall**  
engineering since 1915  
1661 International Drive • Memphis, TN 38120  
901 820 0820 • fax 901 683 1001  
www.allenhoshall.com



REVISIONS:

DATE:  
AUGUST 28, 2012

DRAWN BY:  
AMB

SHEET TITLE:  
FLOOR PLAN-  
BELOW FLOOR  
PLUMBING

SHEET NO:

P1.1